

WAC 246-215-05280 Operation and maintenance—Scheduling inspection and service for water system device (2009 FDA Food Code 5-205.13). A device such as a water treatment device or backflow preventer must be scheduled for inspection and service, in accordance with manufacturer's instructions and as necessary to prevent device failure based on local water conditions, and records demonstrating inspection and service must be maintained by the PERSON IN CHARGE.

[Statutory Authority: RCW 43.20.050 and 43.20.145. WSR 13-03-109, § 246-215-05280, filed 1/17/13, effective 5/1/13.]